



LiFePo4 Battery

Installation, Operation and Servicing Instructions

 A black rectangular lithium battery with a white label. The label features the eGen logo and text: "150AH Lithium Battery with Bluetooth 12.8V (3.2V/100Ah)", "12.8V (3.2V/100Ah)", and "LiFePO4 BATTERY". A QR code is visible in the bottom right corner of the label. A black carrying handle is attached to the top of the battery.	 A black rectangular lithium battery, similar in design to the 150AH model. The label features the eGen logo and text: "200AH Lithium Battery with Bluetooth 12.8V (3.2V/100Ah)", "12.8V (3.2V/100Ah)", and "LiFePO4 BATTERY". A QR code is visible in the bottom right corner of the label. A black carrying handle is attached to the top of the battery.
<p>Part No. 054869</p>	<p>Part No. 054870</p>

NOTE: Please read this manual carefully before installing and using this product.

Table of Contents

1	General Safety Instructions.....	2
2	Safety Warnings	2
3	Installation Instructions	3
3.1	Before Installation.....	3
3.2	Parallel or Series Connection	3
4	Battery Storage.....	4
5	Technical Data and Specifications.....	5
6	Warranty	6

Scan the QR code to download the
eGen LiFe Battery App



1. General Safety Instructions

It is important and necessary to read the user manual carefully before installing or using the battery. All battery installation must be carried out by a qualified person in accordance with AS/NZS 3001 Electrical Installations. Camec does not assume any liability for damages or injuries due to incorrect installation and/or improper use.

2. Safety Warnings

- **DO NOT** heat the battery or throw it into fire or water.
- **DO NOT** use sharp objects to pierce the battery.
- **DO NOT** disassemble the battery.
- **DO NOT** use batteries that are severely scratched or deformed.
- **DO NOT** use battery with other battery type, model and/or brand.
- **DO NOT** use metal conductors to touch the battery's positive and negative terminals. This will cause battery short circuit.
- **DO NOT** connect the positive and negative battery terminal in a reverse manner when installing the device.
- **DO NOT** use batteries if it becomes hot, emits an odor, discoloration, deformation or other abnormalities found during use, charge or storage.
- **DO NOT** use battery charger that are not suitable for charging LiFePo4 batteries.
- **DO NOT** exceed the battery temperature limit during use, charging and discharging.
- **DO NOT** connect the battery to the device when not in use for long time. The battery should be removed from the device and stored under the recommended storage conditions.
- **DO NOT** store or place any metal objects such as necklaces, hairpins, coins or screws on the battery.

- **DO NOT** allow use by persons (including children) with reduced physical, sensory or mental capabilities, or lack of experience and knowledge, unless they have been given supervision or instruction concerning use of the product by a person responsible for their safety.

3. Installation Instructions

- Battery should be placed on a firm, flat surface. If necessary, a battery baffle should be used to ensure that it will not slip or fall during normal use.
- Battery has an ABS outer shell. There should be a minimum gap clearance of 15mm around the battery when installed.
- For maximum product performance and safety, it is recommended to use a torque wrench when installing the pole screw with the recommended tightening torque.

3.1. Before Installation

Check and inspect batteries before installation:


- Battery surface is clean and dry. Ensure that there are no physical defects on the battery e.g. outer shell is not damaged, pole is not rusted.
- Check the battery model is correct, as required.

3.2. Parallel or Series Connection

When connecting batteries in series or parallel, refer to below instructions:

- Ensure each battery is within range of 200mV (0.2V) after a full charge (before connection). This will minimise the chance of an imbalance between batteries. If voltage of any battery is >200mV (0.2V) from other batteries, charge the battery individually to rebalance.
- Batteries connected in series are best charged individually. Charging in series connection can lead to imbalances and reduced runtime, which will require individual charging to maintain balance.

- Maximum of 4 units batteries can be connected in series or parallel. Batteries needs to be in same batch in order to ensure consistency. Please contact Camec National Customer Support Team for assistance before installation.



4. Battery Storage

It is recommended to cycle the batteries at least every 3 months when store for long periods of time, to ensure the batteries are at 50%-100% state of charge (SOC).

Please note if the battery is not charged for a long period of time, the battery voltage will be lower than the BMS over-discharge protection voltage due to the prolonged self-discharging and will lead to battery failure.

5. Technical Data and Specifications

Electrical		
Nominal Voltage (V)	12.8	12.8
Nominal Capacity (Ah)	150	200
Rated Energy (Wh)	1920	2560
Charge Cut-off Voltage (V)	14.6	14.6
Discharge Cut-off Voltage (V)	10	10
Life Cycle @ 80% DoD (Cycle)	6,000	4,000
Standard Charge Current (A)	50	100
Max. Charge Current (A)	100	200
Continuous Discharge Current (A)	150	200
Maximum Discharge Current @ 10s (A)	300	400
Mechanical		
Dimensions (mm)	L345*W190*H245	L345*W190*H245
Weight (kg)	15	22
Terminal	M8	M8
Casing	ABS	ABS
Environment		
Working Temperature (°C)	-20 to 65°C	-20 to 65°C
Humidity Range (RH)	5~75%	5~75%
Storage Temperature (°C)	-20 to 45°C	-20 to 45°C
IP Protection Level	IP67	IP67

6. Warranty

This product is covered under a 36 months warranty period. Kindly refer to the warranty policy terms and conditions available on Camec website.

For further information or assistance, please contact our National Customer Support Team or visit Camec website.

1. Australia on 1300 422 632 or camec.com.au
2. New Zealand on 09 257 2419 or camec.co.nz

For any retail or trade enquiries, please contact our Sales office.

CAMEC VICTORIA

23-27 Freight Drive
Somerton VIC 3062
Phone: 1300 422 632

CAMEC NEW ZEALAND

44 Montgomerie Road
Mangere Auckland 2022
Phone: (09) 2572419

CAMEC NEW SOUTH WALES

Units 2 & 3 No. 1 Koonya Circuit
Caringbah NSW 2229
Phone: (02) 9525 2588

CAMEC QUEENSLAND

Building 3 Archerfield Industrial Park
Cnr Kerry & Beaudesert Road
Archerfield QLD 4108
Phone: (07) 3710 9000

CAMEC WESTERN AUSTRALIA 190

Welshpool Road
Welshpool WA 6106
Phone: (08) 9351 0044